

2020 WATER QUALITY REPORT FOR CENTER POINT WATER SUPPLY

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Lead (ppb)	AL=15 (0)	90th	3.10 (ND - 6)	August 2020	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.565 (0.0786 - 0.964)	August 2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	2.7 (1.8 - 3.9)	12/31/2020	No	Water additive used to control microbes
01 - TAP AFTER RESERVOIR, #4 & #5						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	3.7	01/08/2018	No	Erosion of natural deposits
Combined Radium (pCi/L)	5 (0)	SGL	2.5	01/08/2018	No	Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	20.2	04/03/2019	No	Erosion of natural deposits; Added to water during treatment process
02 - FINISHED WATER SAMPLE TAP, #6						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	14	01/08/2018	No	Erosion of natural deposits
Combined Radium (pCi/L)	5 (0)	RAA	4.4 (3.0 - 5.4)	12/31/2020	No	Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	57.4	04/19/2018	No	Erosion of natural deposits; Added to water during treatment process

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **ppb** -- parts per billion.
- **ppm** -- parts per million.
- **pCi/L** – picocuries per liter
- **N/A** – Not applicable
- **ND** -- Not detected
- **RAA** – Running Annual Average
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.